

# Primary energy and cost implications of low temperature district heat to new residential areas

Leif Gustavsson and Nguyen Le Truong  
Linnaeus University, 351-95 Växjö, Sweden




# Objectives

We analyze cost and energy efficiency of different **district heat distribution alternatives** to a newly planned residential area in Växjö, Sweden



# Location of Växjö, Sweden in Europe




# Project site and situations in Växjö

- Växjö is a city of about 65 000 inhabitants
- With a district heating system (DHS)
  - $\sim 185 \text{ MW}_{\text{peak}}$  and  $\sim 630 \text{ GWh}_{\text{heat}}/\text{year}$
  - $\sim 98\%$  of production is based on biomass
  - Two CHP plants and several boilers



## Measured temperatures in 2013





# Four land exploitation alternatives



Low exploitation of row houses and villas,  
9010 m<sup>2</sup> heated floor area



Medium-exploitation of apartment buildings and  
row houses, 23 540 m<sup>2</sup> heated floor area



High-exploitation of apartment buildings,  
29 350 m<sup>2</sup> heated floor area



Dense-exploitation of apartment buildings,  
41 727 m<sup>2</sup> heated floor area

# Number of buildings

---

Land exploitation	Villas	Row houses	6-storey buildings	8-storey buildings	10-storey buildings
Low	39	29	-	-	-
Medium	21	29	8	-	-
High	-	29	15	-	-
Dense	-	29	-	13	3

---



# We consider for each land exploitation alternative

- Two building energy efficiency levels
  - Swedish building code (BBR 2015)
  - Swedish passive house criteria (Passive 2012)
- Three different district heat supply/ return temperatures
  - 80/40°C (conventional system)
  - 65/30°C
  - 50/20°C



# Key energy properties of building code and passive house buildings

Description	U-values	
	Building code	Passive house
Ground floor	0.11	0.11
Exterior walls	0.33	0.10
Windows	1.2	0.8
Doors	1.2	0.8
Roof	0.13	0.05
Infiltration (l/s m <sup>2</sup> @50 Pa)	0.8	0.3
Mechanical ventilation	80% heat recovery	80% heat recovery






# Space heating capacity (kW)


House/building type	Building standard	
	Building code	Passive house
Villas		
o 100 m <sup>2</sup>	5.68	2.06
o 110 m <sup>2</sup>	5.81	2.16
o 120 m <sup>2</sup>	5.94	2.26
o 150 m <sup>2</sup>	6.32	2.55
Row houses		
o Type 1 (Regular)		
Beginning	5.78	2.14
Middle row	3.99	1.80
End	5.87	2.29
o Type 2 (Offset of walls)		
Beginning	5.78	2.14
Middle row	4.34	1.93
End	6.20	2.42
Multi-apartment buildings		
o 6-storey, 24 apartments	54.47	27.82
o 8-storey, 32 apartments	70.96	36.28
o 10-storey, 40 apartments	87.46	44.80



# Space- and hot water heating



Building code





Passive house


Based on hour by hour energy balance calculations




# Annual heat demand for space and hot water heating



# Heat supply network




Low exploitation, 1718m




Medium exploitation, 1686m



# Heat supply network




High exploitation, 1341m




Dense exploitation, 1351m



# District heat distribution losses



Building code




Passive house






# District heat use, electricity use and distribution losses



Building code



Passive house


Reduced district heat distribution losses compared to the 80/40°C system

65/30°C system 24-25%


50/20°C system 48-50%



# Annual changed final energy use when lower supply/return temperatures are used instead of a 80/40°C system




Building code




Passive house



# Investment costs for networks and substations



Building code



Passive house



# Cost implication of reduced supply/return temperatures in local network with 80/40°C as baseline

The net present value of

- ❖ reduced distribution network heat losses and reduced use of district heat

minus

- ❖ increased use of electricity for pumping and boosting hot water temperature


and minus

- ❖ the increased investment cost for the low district heat temperature alternatives

is calculated assuming different real discount rates and lifetimes



# District heat and electricity cost




- ❑ Marginal costs of district heat production: 29.1 €/MWh
- ❑ Costs of electricity use: 92.6 €/MWh



# Changed cost of lower district heat temperatures – discount rate 6%, lifetime 30 years


Negative values are cost increase






# Changed cost of lower district heat temperatures – discount rate 3%, lifetime 45 years


Negative values are cost increase



# Changed primary energy use for lower district heat temperatures - coal-based power plants




Building code




Passive house



# Changed primary energy use for lower district heat temperatures - fossil gas-based power plants





Building code



Passive house




# Changed CO<sub>2</sub> emission for lower district heat temperatures - coal-based power plants



# Bioenergy based production

Costs are based on cost-optimal bio-based district heat production using 2013 heat load curve in Växjö and biopower production including capital costs




Costs of district heat production: 34.8 €/MWh


Costs of biomass-based electricity: 95.2 €/MWh

# Changed cost of lower district heat temperatures – discount rate 6%, lifetime 30 years, bio-based production

Negative values are cost increase



Building code




Passive house






# Changed primary energy use for lower district heat temperatures – bio-based production



Building code




Passive house




# Changed primary energy use for lower district heat temperatures

## – bio-based production + 25% wind power

(no primary energy use for wind power)



Building code



Passive house



## **Not considered**

1. District heat production benefits of operating CHP-plants (heat pumps, waste heat, etc) at lower district heating temperatures
2. Reduced distribution heat losses in the overall distribution system due to lower supply/return temperatures
3. Implications on internal space heat distribution in buildings due to lower supply/return temperatures
4. Plastic pipes for district heat distribution

# Discussion and Conclusions

1. Heat demand of a residential area depends strongly on building energy performance and land exploitation level
2. The heat density of the residential areas has a minor impact on the local district heat distribution losses
3. Reduced district heat supply/return temperatures strongly reduce the local district heat distribution losses
4. A 50/20°C system increases electricity use, to boost hot water temperature to avoid the risk of legionella bacteria
5. A 65/30°C system may be more cost and primary energy efficient when a 50/20°C



*Thank you!*

