





International Conference on Smart Energy Systems and 4th Generation
District Heating, Copenhagen, 25-26 August 2015



Environomic Assessment of Industrial Surplus Heat Transportation



Justin NW. Chiu, PhD¹

J. Castro Flores, MSc^{1,2}

Prof. V. Martin¹

Assoc. Prof. O. Le Corre²

Assoc. Prof. B. Lacarrière²

KTH- Royal Institute of Technology Stockholm,
Sweden¹

École des Mines de Nantes, France²



AALBORG UNIVERSITY
DENMARK

4DH

4th Generation District Heating
Technologies and Systems



Table of Content



- 1. Introduction
- 2. Methodology
- 3. Results
 - 3.1. Case Study
 - 3.2. CO₂ Emission in Cost Optimized Scenarios
 - 3.3. Sensitivity Analysis
- 4. Conclusion
- 5. Future Work






1. Introduction



Industrial sector: 20% - 50% energy released to the ambient
Building sector: represents 40% total energy use



Objective: Use industrial surplus heat in district heating via mobile thermal energy storage (M-TES)
→ load shift in space and time





2. Methodology



- High energy storage density
- Sufficient thermal charge/discharge rate
- Transportation flexibility
- Cost effectiveness




2.1. Latent Heat Storage



PCMs have


- small temperature swing
- large enthalpy
- application-suited working temperature range



Erythritol	
Phase Change Energy Storage Capacity	330 [kJ/kg] / 92 [kWh/ton]
Peak melting point	~110 [°C]
Density	1480 [kg/m ³] in solid state 1300 [kg/m ³] in liquid state
Viscosity	2.90 × 10 ⁻² [Pa s] (Solid) 1.60 × 10 ⁻² [Pa s] (Liquid)
Thermal Conductivity	0.326 [W/m-K]



2.2. Performance Mapping



International Conference on Smart Energy Systems and 4th Generation District Heating, Copenhagen, 25-26 August 2015

Source: Chiu et al, Applied Energy, 2013



2.3. Techno-Economic Optimization





- Objective Functions:
 1. Minimize CAPEX
 2. For the minimum CAPEX, minimize OPEX
- Constraints:
 1. User load profile
 2. Case specific boundaries
- Variables:
 1. Operating conditions
 2. Logistics/ Operating mode



3. Results

3.1. Case Study Hedesunda





Winter time → 10X higher thermal power demand



3.1. Case Study: Hedesunda



Non Optimized Operating Strategy with full Storage



Reduced number of MTES by 33% if control strategy is optimized for high thermal power demand period

High thermal power demand → Partial storage for minimum number of MTES

Low thermal power demand → Full storage for maximum capacity per trip, min number of trips



3.1. Case Study: Hedesunda




Component	Cost
PCM	20 €/kWh
Heat Exchanger and Tank	160 €/m ² heat transfer area for 40 foot container
Auxiliary Components	20% of MTES unit cost
Substations	45 k€ for the considered case
Transportation Cost	1€/km, 0.4€/km and 0.1€/km for road, rail and maritime
Operation and Maintenance	Replacement of PCM after 5'000 cycles
Transportation CO ₂ emission	Maritime: 9 g/km Rail: 20 g/km Road: 900 g/km

Goal	
Discount Rate	4%
Pay Back Time	12 years

	Maritime	Rail	Road
Optimal Cost Scenario	49 €/MWh	62 €/MWh	86 €/MWh



3.2. CO₂ Emission in Cost Optimized Scenarios



In comparison with boiler:

Diesel: 216 kg/MWh


LPG: 136 kg/MWh

Biomass: carbon neutral?

- Lower CO₂ emission with Maritime (100X) and Rail (50X) as compared to Road
- Lower user load demand → lower CO₂




3.2. CO₂ Emission in Cost Optimized Scenarios



Cost optimized scenarios lead to 20% cost reduction but brings 3% - 8% of CO₂ increase due to operating mode with more frequent transport.




3.3. Sensitivity Analysis



- **PCM price** and **storage performance** have a preponderant impact on **low cost slower transportation** scenarios
- **Operation optimization** and **logistics** is reflected more on **high cost fast transportation** scenarios



3.3. Sensitivity Analysis- Söderfors



	Maritime	Rail	Road
Optimal Cost Scenario	57 €/MWh	76 €/MWh	123 €/MWh

	Site H	Site S
PER	181 mth ⁻¹	191 mth ⁻¹
Distance	48 km	58 km
Annual Demand	4.3 GWh	7.2 GWh
Average CO2 by Road	550 kg/MWh/yr	600 kg/MWh/yr

PER= Peak power to average load ratio



4. Conclusion



- Approved concept
- PCM selection → M-TES setup → Logistics modeling → Economic Optimization → Environomic performance
- Economic viability with fast and cheap transportation, optimized operating strategy, enhanced storage performance and low material/component cost
- Economic optimum as trade off to environmental benignity



5. Future Work



- Experimental and pilot plant validation
- Complete environomic scenario mapping of full range end-user power to energy profiles





Thank You for Your Attention

Justin.chiu@energy.kth.se

+ 46 (0) 8790 7414

